TSURUMI PUMP

FEATURES

- 1. Semi-vortex , FRP (Fiberglass Reinforced Plastic), impeller passes solids and stringy material without clogging and increases wear resistance when pumpage contains abrasive particles.
- 2. Double inside mechanical seals with silicon carbide faces, running in an oil filled chamber and further protected by a lip seal, provides for the most durable seal design available.
- 2. Highly efficient, continuous duty, air filled, copper wound motor with class E insulation minimizes the cost of operation.
- 4. Built in thermal & amperage sensing, protector prevents motor failure due to overloading, single phasing (in three phase units), or accidental run -dry conditions.

5. Double shielded, permanently lubricated, high temperature C3 ball bearings rated for a B-10 life of 60,000 hours. extend operational life.

VANCS - SERIES - TM

(FRP) SEMI-VORTEX - SEA WATER PUMPS

6. Utilization of application appropriate FRP & Titanium components increases corrosion resistance in a wide variety of applications.

APPLICATIONS

- 1.Salt wastewater and site drainage.
- 2. Chemical spill containment.
- 3. Decorative waterfalls, salt water, fountains and fish ponds.
- 4. Bilge pumps.
- 5.Salt water aquiculture.

SPECIFICATIONS

Discharge Size Horsepower Range Performance Range Capacity Head Maximum water temperature Materials of Construction Casing (upper)/(lower) Impeller Shaft Motor Frame Fasteners

Mechanical Seal Elastomers

Impeller Type Solids Handling Capability

Bearings

Motor Nomenclature Type, Speed, Hz. Voltage, Phase Insulation

Accessories

Operational Mode

STANDARD 2" ~ 3" NPT (50 ~ 80mm) 1/3 ~ 5HP. (.25 ~ 3.7 Kw) 10.6 ~ 224.6 GPM. (.04 ~ .85 m³/min) 10.7 Ft. ~ 94.2 Ft. (3.25 ~ 28.71 m) 104° F. (40° C.)

FRP (ABS + G20) / ABS FRP (PPO + G20) Titanium Titanium Titanium

Silicon Carbide NBR (Nitril Buna Rubber)

Semi-Vortex, solids handling. .4" ~ .8" (10 ~ 20 mm)

Pre-lubricated, Double Shielded

Air Filled, 3600 RPM, 60 Hz. 115 or 230 V.,1 Phase., 208-220, 230, 460, or 575 V., 3 Phase. Class E

Submersible Power Cable 32' (10 m)

Length as Required

TMBI -P1





ANCS

OPTIONS




60-PC-TM-00




TSURUMI PUMP

VANCS - SERIES - TM (FRP) SEMI-VORTEX - SEAWATER PUMPS










C.W.L. : Continuous running Water Level L.W.L. : Lowest running Wtaer Level

DIMENSIONS:USCS (Inch)														
Г	Model	HP	NOM.	Pump & Motor								C.W.L.	L.W.L.	Wt.
			SIZE	Α	A1	A2	В	D	D1	D2	Н	W1	W2	(lbs.)
	80TM22.2-61	3	3"	12 1/4	6 1/8	4 1/8	4 5/16	8 3/8	4 1/8	4 1/4	22	19 5/8	5 1/8	46
	80TM23.7-61	5	3"	12 1/4	6 1/8	4 1/8	4 5/16	8 3/8	4 1/8	4 1/4	23 3/8	21 1/8	5 1/8	57
		-										-		

DIMENSIONS:METRIC (mm) kW NOM Pump & Motor C.W.L. L.W.L Wt. Model SIZE A1 A2 В D D1 D2 Н W1 W2 Α (kg) 80TM22.2-61 2.2 80 311 155 105 110 212 104 108 559 500 130 21 80TM23.7-61 155 105 110 104 108 594 535 130 3.7 80 311 212 26

Feb. 11





VANCS - SERIES - TM (FRP) SEMI-VORTEX - SEA WATER PUMPS

SAMPLE SPECIFICATIONS

1. SCOPE OF SUPPLY -

Furnish and install TSURUMI, VANCS Model ______ Submersible Pump(s). Each unit shall be capable of delivering _____GPM(____m³/min) at _____Feet (_____m) TDH. The pump(s) shall be designed to pump waste water, seawater or effluent containing _____ inch (____mm) diameter solids without damage during operation. The pump(s) shall be designed so that the shaft power required (BHP)/(kW) shall not exceed the motor rated output throughout the entire operating range of the pump performance curve. The pump discharge size shall be____inch, (____mm).

2. MATERIALS OF CONSTRUCTION -

Construction of major parts of the pumping unit(s) including pump casing, impeller, motor head cover and intermediate brackets shall be manufactured from recyclable, application appropriate resins. The need for a protective coating shall not be required. All exposed fasteners shall be Titanium and shall have Titanium mating anchors integrally cast into the mating part. All units shall be furnished with a NPT discharge companion flange. Impellers shall be of the multi-vane, semi-vortex, solids handling design and shall be slip fit to the shaft. The motor shaft shall be machined to provide a positive drive of the impeller. The pump casing shall incorporate an air relief valve.

3. MECHANICAL SEAL -

All units shall be furnished with a dual inside mechanical shaft seal located completely out of the pumpage, running in a separate oil filled chamber. Units shall be fitted with a device that shall provide positive lubrication of top mechanical seal, (down to one third of the standard oil level). The device shall not consume any additional electrical power. Units shall have silicon carbide mechanical seal faces. Mechanical seal hardware shall be Stainless steel.

4. MOTOR -

The pump motor(s) shall be _____Hp., _____kW., _____V, 60 Hz., ___Phase and shall be NEMA MG-1, Design Type B equivalent. Motor(s) shall be rated at ______ full load amps. Motor(s) shall have a 1.15 service factor and shall be rated for 6 starts per hour. Motor(s) shall be air filled, copper wound, class E insulated with built in thermal and over amperage protection. Motor shaft shall be Titanium and shall be supported by two permanently lubricated, high temperature ball bearings, with a B-10 life rating at best efficiency point of 60,000 hours. The bearings shall be single row, double shielded, C3, deep groove type ball bearings. Bearing seats shall be rolled carbon steel or aluminum die casting. Motor housing shall be Titanium. Motors shall be suitable variable speed applications, utilizing a properly sized variable frequency drive. (Only for 3phase)

5. POWER CABLE AND CABLE ENTRANCE -

The pump power cable shall be suitable for submersible pump applications. The cable entrance shall incorporate built in strain relief, a one piece, three way mechanical compression seal with a fatigue reducing cable boot. The cable entrance assembly shall contain an anti-wicking block to eliminate water incursion into the motor due to Capillary wicking should the power cable be accidentally damaged.