

VANCS SERIES - PSF

(FRP) EFFLUENT PUMPS

Specifications

FEATURES

- 1. Enclosed, FRP (Fiberglass Reinforced Plastic), impeller provides for high head pumping of effluent or water.
- 2. Double inside mechanical seals with silicon carbide faces, running in an oil filled chamber and further protected by a lip seal, provides for the most durable seal design available.
- 2. Highly efficient, continuous duty, air filled, copper wound motor with class E, insulation minimizes the cost of operation.
- 4. Built in thermal & amperage sensing, protector prevents motor failure due to overloading, 2. Chemical spill containment. single phasing (in three phase units), or accidental run -dry conditions.

- 5. Double shielded, permanently lubricated, high temperature C3 ball bearings rated for a B-10 life of 60,000 hours, extend operational life.
- 6. Utilization of application appropriate FRP & stainless steel components increases corrosion resistance in a wide variety of applications.

APPLICATIONS

- 1. Residential, commercial, effluent, wastewater and site drainage.
- 3. Decorative waterfalls, fountains and fish ponds.
- 4. Raw water supply from rivers or lakes.







■ SPECIFICATIONS

Discharge Size Horsepower Range Performance Range Capacity Head

Maximum water temperature Materials of Construction

Casing (upper)/(lower)

Impeller Shaft

Motor Frame

Fasteners

Mechanical Seal Elastomers

Impeller Type Solids Handling Capability

Bearings

Motor Nomenclature Type, Speed, Hz. Voltage, Phase

Insulation

Accessories

Operational Mode

■ STANDARD

2" ~ 3" N.P.T. (50 ~ 80mm) $1/3 \sim 5$ Hp. (.25 ~ 3.7 kW) $6.6 \sim 203.4 \text{ G.P.M.} (.03 \sim .85 \text{ m}^3/\text{min})$ 16.4 ~ 111.5 Ft. (5.0 ~ 33.99 m) 104° F. (40° C.)

FRP (ABS + G20) / ABS FRP (ABS + G20) 403 Stainless Steel 304 Stainless Steel 304 Stainless Steel

Silicon Carbide NBR (Nitril Buna Rubber)

Enclosed, Multi-vane .32 ~.51" (8~13 mm)

Pre-lubricated, Double Shielded

Air Filled, 3600 Rpm, 60 Hz. 115 or 230 V.,1 Phase., 208-220, 230, 460, or 575 V. 3 Phase Class E

Submersible Power Cable 32' (10 m)

OPTIONS

Length as Required Model A(Automatic), Model AW (Automatic Alternating) TOK (FRP) Slide rail system Aug-17 60-PC-PSF-00




VANCS - SERIES - PSF

(FRP) EFFLUENT PUMPS

PERFORMANCE RANGE

GROUP PERFORMANCE RANGE



CAPACITY

Note	•			


ug. 06 60-PC-PSF-04



VANCS - SERIES - PSF (FRP) EFFLUENT PUMPS

PERFORMANCE CURVE

MODEL		BORE	HP	KW	RPM	SOLIDS DI	Α	LIQUID	SG.	VISC	OSITY	TEMP.
50PSF(A/W)2.4	-62	2" / 50mm	0.54	0.40	3397	0.315" / 8mm		Water	1.0	1.12	3 cSt.	60°F
PUMP TYPE		PHASE	VOL	TAGE	AM	MPERAGE HZ STARTING METHOD I		STARTING METHOD		INS. C	CLASS	
Effluent Pump)	3	230	/ 460	1	.9 / 1.0	60	Direct On	Line		I	E
CURVE No.	DATE	PHASE	VOL	TAGE	AM	PERAGE	HZ	STARTING N	/ETHC	D	INS. C	CLASS
-	-	-		-		-	-	-				-




F-DM-PSF-03




VANCS - SERIES - PSF (FRP) EFFLUENT PUMPS

DIMENSIONS



50PSFA2.25S-62 50PSFA2.4S-62 50PSFA2.4-62 50PSFA2.75S-62 50PSFA2.75-62



DIM ENSIONS: USCS (Inch)

Bill Eliototic (coop (mon)													
Model	HP	NOM.		Pump & Motor						Stop	Start	Wt.	
		SIZE	Α	A1	A2	В	D	D1	D2	Н	FL1	Max.FL2	(lbs.)
50PSFA2.25S-62	1/3	2"	9 5/16	4 1/2	3 3/16	4	6 13/16	3	3 13/16	14 3/4	4 1/2	23 7/8	17.2
50PSFA2.25-62	1/3	2"	9 5/16	4 1/2	3 3/16	4	6 13/16	3	3 13/16	14 5/16	4 1/2	23 1/2	15.0
50PSFA2.4S-62	1/2	2"	9 5/16	4 1/2	3 3/16	4	6 13/16	3	3 13/16	14 3/4	4 1/2	23 7/8	17.2
50PSFA2.4-62	1/2	2"	9 5/16	4 1/2	3 3/16	4	6 13/16	3	3 13/16	14 3/4	4 1/2	23 7/8	17.0
50PSFA2.75S-62	1	2"	9 5/16	4 1/2	3 3/16	4	6 13/16	3	3 13/16	15 1/2	4 1/2	24 5/8	21.1
50PSFA2.75-62	1	2"	9 5/16	4 1/2	3 3/16	4	6 13/16	3	3 13/16	15 1/4	4 1/2	24 1/2	19.8


DIM ENSIONS:METRIC (mm)

DIM ENSIONS.M ET RIC (III III)													
Model	kW	NOM.		Pump & Motor						Stop	Start	Wt.	
		SIZE	Α	A1	A2	В	D	D1	D2	Н	FL1	Max.FL2	(kg)
50PSFA2.25S-62	0.25	50	236	115	81	102	173	76	97	374	115	607	7.8
50PSFA2.25-62	0.25	50	236	115	81	102	173	76	97	363	115	596	6.8
50PSFA2.4S-62	0.40	50	236	115	81	102	173	76	97	374	115	607	7.8
50PSFA2.4-62	0.40	50	236	115	81	102	173	76	97	374	115	607	7.7
50PSFA2.75S-62	0.75	50	236	115	81	102	173	76	97	394	115	627	9.6
50PSFA2.75-62	0.75	50	236	115	81	102	173	76	97	388	115	621	9.0



VANCS - SERIES - PSF (FRP) EFFLUENT PUMPS

SECTIONAL VIEW



PART#	DESCRIPTION	MAIN MATERIAL / NOTE	RELATED ASTM, AISI CODE	RELATED EN CODE	QTY
1	Power Cable	PVC Sheath AWG16/4-32ft			1
20	Pump Casing	ABS Plastic w/GF20			1
21	Impeller	PPO Plastic w/GF20			1
23	Suction Strainer	ABS Plastic			1
25	Mechanical Seal	Silicon Carbide / W-14HL			1
29	Oil Casing	PPS Plastic w/GF40			1
30	Oil Lifter	PBT Plastic			1
35	Oil Plug	Stainless Steel	S 30400	1.4301	1
36	Lubricant	White Mineral Oil ISO VG32			
46	Air Valve	Glass Ball			1
48	Companion Flange	PBT Plastic w/GF30 / NPT 2"			1
50	Motor Bracket	Aluminum Alloy Die Casting	B85 383.0	EN 1706 AC-46100	1
51	Motor Head Cover	PPS Plastic w/GF40			1
52A	Upper Bearing	#6201ZZC3			1
52B	Lower Bearing	#6202ZZC3			1
53	Motor Protector				1
54	Shaft	Stainless Steel	S 30400	1.4301	1
55	Rotor				1
56	Stator				1
60	Bearing Housing	Aluminum Alloy Die Casting	B85 383.0	EN 1706 AC-46100	1
64	Motor Housing	Stainless Steel	S 30400	1.4301	1
106	Float Set	ABS Plastic			2
	Float Support Pipe	PVC			1
114	Power Relay				1
115	Transformer				1

Oct. 13 60-SS-PSF-01



VANCS - SERIES - PSF (FRP) EFFLUENT PUMPS

SAMPLE SPECIFICATIONS

(****)	OI LOII IOATION
1. SCOPE OF SUPPLY -	
Furnish and install TSURUMI, VANCS Model Submersible Pump(s). capable of delivering GPM(m³/min) at Feet (m) TDH. designed to pump waste water, sewage or effluent containing inch (mm) dian damage during operation. The pump(s) shall be designed so that the shaft power required exceed the motor rated output throughout the entire operating range of the pump performa discharge size shall beinch, (mm).	neter solids without (BHP)/(kW) shall not
2. MATERIALS OF CONSTRUCTION -	
Construction of major parts of the pumping unit(s) including pump casing, impeller, motor hintermediate brackets shall be manufactured from recyclable, application appropriate resing protective coating shall not be required. All exposed fasteners shall be stainless steel and steel mating anchors integrally cast into the mating part. All units shall be furnished with a companion flange. Impellers shall be of the multi-vane, enclosed design and shall be slip f motor shaft shall be machined to provide a positive drive of the impeller. The pump casing relief valve.	s. The need for a shall have stainless NPT discharge it to the shaft. The
3. MECHANICAL SEAL -	
All units shall be furnished with a dual inside mechanical shaft seal located completely running in a separate oil filled chamber. Units shall be fitted with a device that shall provide top mechanical seal, (down to one third of the standard oil level). The device shall not conelectrical power. Units shall have silicon carbide mechanical seal faces. Mechanical seal Stainless steel.	e positive lubrication of sume any additional
4. MOTOR -	
The pump motor(s) shall beHp.,kW.,V., 60 Hz.,Phase and shall Design Type B equivalent. Motor(s) shall be rated at full load amps. Motor(s) shall factor and shall be rated for 6 starts per hour. Motor(s) shall be air filled, copper wound, cloult in thermal and over amperage protection. Motor shaft shall be 304 stainless steel and two permanently lubricated, high temperature ball bearings, with a B-10 life rating at best e 60,000 hours. The bearings shall be single row, double shielded, C3, deep groove type baseats shall be rolled carbon steel or aluminum die casting. Motor housing shall be 304 stainless.	ass E insulated with I shall be supported by Ifficiency point of Ill bearings. Bearing
5. POWER CABLE AND CABLE ENTRANCE -	
The pump power cable shall be suitable for submersible pump applications. The cable en built in strain relief, a one piece, three way mechanical compression seal with a fatigue re cable entrance assembly shall contain an anti-wicking block to eliminate water incursion in Capillary wicking should the power cable be accidentally damaged.	ducing cable boot. The